

BRIGHTON AREA FIRE DEPARTMENT WATER FLOW PROCEDURES

If an automatic fire suppression system is being installed, current water flow information must be obtained. Arrangements to flow hydrants to obtain water flow information should be made with the appropriate water authority listed below. When an appointment has been secured from the proper water authority, contact the Brighton Area Fire Department – Fire Prevention Division with the time, date and location of the hydrant and jurisdiction. It is a requirement for the Brighton Area Fire Department to witness the hydrant flow test for information verification. Call 810-225-8033 or fax 810-225-8036 with your request to witness a water flow test.

Flow test procedures shall comply with NFPA 24 (Standard for the installation of private fire service mains and their appurtenances).

Contact the Brighton Area Fire Department Fire Prevention Division with the specific location of any new fire hydrant installation for correct thread and adapter requirements. Hydrant connections shall comply with NFPA 1963 (Standard for fire hose connections.)

Contact the appropriate water authority for the proper required backflow device used in that jurisdiction.

City of Brighton Water Authority:

Mr. Tim Krugh

Office phone: 810-227-9479

Office fax: 810-227-7635

Brighton Township Water Authority

Fonda Island-Briggs Lake Joint Water Authority

Email: fibwater@sbcglobal.net

Office phone: 810-227-4149 Hours: Mon./Tues./Wed. 9:00 am till 3:00 pm

Emergency phone: 810-229-7970

Earthtech phone: 800-997-7232

Grand River/Old Us-23 Area

Highland Treatment Inc.

Office phone: 248-889-1922

Office fax: 248-887-6256

Genoa Township Water Authority

MHOG (Marion, Howell, Oceola, Genoa)

Mr. Greg Tatara

Office phone: 810-227-5225

Office fax: 810-227-3420